



# Certificat

## Certificate

### Certificate of constancy of performance for products

In compliance with the Regulation 305/2011/UE of the European Parliament and of the Council of 9 March 2011.  
(Construction Products Regulation or CPR)

**Delivered by :**

Notified Body :

**AFNOR Certification**

Identification number :

**0333**

Address :

**11 rue Francis de Pressensé  
FR - 93571 LA PLAINE SAINT-DENIS CEDEX**

**Delivered to :**

Company:

**FINSECUR**

Address :

**62, rue Ernest Renan  
92000 NANTERRE - France**

Manufacturing site(s) :

**Poissy - France  
Duttlenheim - France**

**Product : Manual call point using radio links - Sextant-DMR**

**Detailed description of product :** Appendix

AFNOR Certification attests that the provisions concerning the assessment and verification of constancy of performance and the performances described in annex ZA of the standard(s), below stated, under system 1 are applied and that the product fulfills the provisions described in annex ZA of the standard(s) below designated.

**Fire detection and fire alarm systems**

**EN 54-11:2001 + A1:2005 - Manual call points**

**EN 54-25:2008 + AC:2010 - Components using radio links**

**Certificate number :**

**0333-CPR-075586**

**Certificate expiry date : 5 July 2024**

This certificate was first issued on 25 April 2018. Unless suspension or canceled, this certificate remains valid as long as the conditions laid down in the reference technical specifications or the manufacturing conditions in the factory or the factory production control or the product itself are not modified significantly.

It cancels and replaces the certificate issued on 26 April 2018.

**Date of certificate delivery : 5 July 2019**



**Franck LEBEUGLE**  
Managing Director of AFNOR Certification

005 - 2018/08 -



# Certificat

Certificate

## Appendix to the certificate

Company : **FINSECUR**  
Certificate number : **0333-CPR-075586**  
Manufacturing site(s) : **Poissy - France  
Duttlenheim - France**  
Date of certificate delivery : **5 July 2019**

### Product's description :

Identification of certified product(s) (Reference)	Product designation / Use	File number
Sextant-DMR	Manual call point using radio links  Type A Environment category : Indoor	075.2055

This appendix cannot be submitted or reproduced without the document to which it is attached.

**Franck LEBEUGLE**  
Managing Director of AFNOR Certification