

Certificate of constancy of performance for products

In compliance with the Regulation 305/2011/UE of the European Parliament and of the Council of 9 March 2011
(Construction Products Regulation or CPR)

Deliver by :

Certification body : **AFNOR Certification**
Identification number : **0333**
Address : **11 rue Francis de Pressensé**
FR - 93571 LA PLAINE SAINT-DENIS CEDEX

Issued to :

Manufacturer : **FINSECUR**

Address :
62, rue Ernest Renan
92000 NANTERRE - France

Manufacturing site :
Poissy - France
Soliman - Tunisie
Hebei Province - Chine

Description of the products: see annex

AFNOR Certification attests that the provisions concerning the assessment and verification of constancy of performance and the performances described in annex ZA of the standard:

EN 54-23:2010

are applied under system 1 and that the product SEXTANT DVAF-C fulfills the provisions described in annex ZA of the standard:
EN 54-23:2010

Certificate number :
0333-CPR-075628

Conditions and certificate validity period: this certificate was first issued on 12/1/2021.

Unless suspended or withdrawn, this certificate remains valid as long as the conditions laid down in the harmonized technical specifications or the manufacturing conditions in the factory or the factory production control itself are not significantly modified.
This certificate cancels and replaces any previous certificate.

Page 1 sur 2

Date of issue of the certificate :
11/7/2022

Certificate expiry date :
11/30/2026

Managing Director of AFNOR Certification
Julien NIZRI



Annex to the certificate issued on 11/7/2022 : 0333-CPR-075628

Manufacturer :

FINSECUR

Manufacturing site:

Poissy - France
Soliman - Tunisie
Hebei Province - Chine

Product description:

Identification of the certified products (reference)	Product designation according to the standard	File number	Use of the products
SEXTANT DVAF-C	Visual alarm device	075.2380	Type A (indoor) Category : C (Ceiling mounted) Light Colour : White

This annex cannot be submitted or reproduced without the document to which it is attached.

Page 2 sur 2

Managing Director of AFNOR Certification
Julien NIZRI

